



OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE, CUTTACK

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire prevention and Fire Safety Rules, 2017)

File No-XI-4-C-21-2024

Certificate No-215 /CR.TC

Dt- 15-10-2024

This Certificate is valid up to 14-10-2024(Midnight)

(Apply for renewal at least three months before expiry)

With reference to your Online Fire Safety Application No FSC1101040012020000046. You have applied for issuance of Fire Safety Certificate in respect of G+1 storied Residential Building in the name of "Satya Sai Gurukul", situated over at- Kenduapada, Dist- Bhadrak, Odisha- 756112 was inspected by officers of Odisha Fire Services on 15-10-2024 in the presence of the Chairman and Principal of "Satya Sai Gurukul" and it has been found to comply with the Fire prevention and safety requirements in accordance with the odisha Fire Prevention and Fire Safety (Amendment) Rules 2019 and one time relaxation scheme vide Home Department Notification No- 28423/CD BBSR. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

G-Floor	----usage----	Reception, Principal Officer, Class Rooms
1-Floor	----usage----	Class Room, Computer Lab
2-Floor	----usage----	Class Room, Science Lab, Library

CONDITIONS:-

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access there to etc provided in the building or premises, should be maintained by the occupied(S) in best repairs and efficient working condition at all times for use by the members of the Fire Service or both in the event of outbreak of fire. Occupants or the
2. The setbacks, driveways, entrance gates, exists, staircases, corridors and escape ways should not be changes, obstructed or modified in any way.
3. The Occupier(S) shall train all staff and occupants periodically to make them well conversant in use and operation fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once six months by involving local fire station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbied/corridor in all floors of all tower/blocks of building/premises.

By order of the Director of Fire Service

Sd/-




Principal

Deputy DIRECTOR OF FIRE OFFICER

BALASORE

Cuttack Circle, Cuttack



Manager
Satyasai Gurukul
Kenduapada, Bhadrak



Principal
Satyasai Gurukul
Kenduapada, Bhadrak